

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7256-0899:0503

Page 1 of 1

CATEGORY: 7256 -- SMOKE ALARM-IONIZATION TYPE (SINGLE/MULTIPLE)

LISTEE: Universal Security Instruments 11407-A Cronhill Dr., Owings Mills, MD 21117
Contact: Stephen Babinec (410) 363-3000 Ext: 214 Fax (410) 363-2218
Email: steveb@universalsecurity.com

DESIGN: Models AMI1061S, AMI1061SB, AMI1061SC, AMI3051S, AMI3051SB, AMIB3051SC, AMIE3051SC, and AMIK3051SC single and/or multiple station, ionization type smoke alarms. Models are provided with 10 year non-replaceable batteries and silence feature. Alarms are intended for indoor residential use only.

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Models AMI1061S, AMI1061SB, AMI1061SC:
120 Vac primary with 2 AA alkaline backup batteries each rated nominal 1.5 Vdc (non-replaceable 10 year)

Models AMI3051S, AMI3051SB, AMIB3051SC, AMIE3051SC, AMIK3051SC:
2 AA alkaline primary batteries each rated nominal 1.5 Vdc (non-replaceable 10 year)

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances, NFPA 72, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or trade name "USI Electric, Inc.", "UNIVERSAL", model number, electrical rating, and ETL label.

APPROVAL: Listed as single and/or multiple station, ionization type residential smoke alarms. Complies with UL 217, 8th Edition. Refer to listee's Installation Instruction Manual for details.

03-02-20 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**

Fire Engineering Division