

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant:	Universal Security Instruments Inc.	Manufacturer:	Eyston
Address:	11407 Cronhill Drive, Suite A Owings Mills, MD 21117	Address:	27 Zheng Tian S. Road, Wei Xing Industrial Zone Yan Tian, Feng Gang, Dongguan, Guangdong
Country:	USA	Country:	China
Contact:	Steve Babinec Harvey Grossblatt	Contact:	Sikker Chan
Phone:	(410) 363-3000 x214 (410) 363-3000 x224	Phone:	852-2557-3135
FAX:	(410) 363-2218	FAX:	852-2897-0249
Email:	steveb@universalsecurity.com Harvey@universalsecurity.com	Email:	asstsales2@Eyston.com
Party Authorized To Apply Mark:	Same as Manufacturer		
Report Issuing Office:	Chicago		
Control Number:	<u>4001042</u>	Authorized by:	 for Dean Davidson, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	Smoke Alarms [UL 217:2015 Ed.8+R:23Nov2016]
Product:	120Vac with non-replaceable 10 year battery back-up, single and/or multiple station smoke alarm; Or, Non-replaceable 10 year primary battery operated single station smoke alarm.
Brand Name:	USI Electric, Inc. or Universal.
Models:	AMI1061S, AMI3051S [Provisional Listing]

ATTENTION: [David.Castillo](#)


CalFire CSFM BML Program Coordinator

**CALIFORNIA DEPARTMENT OF FORESTRY AND FIRE PROTECTION [CAL FIRE]
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING DIVISION
 BUILDINGS MATERIALS LISTING PROGRAM
 1131 "S" STREET
 SACRAMENTO, CA 95811-6524**

This document does not imply product certification with the California State Fire Marshal [CSFM] in accordance with the Building Materials Listing [BML] Program, nor does it imply authorization to apply the ETL Listed Mark. This form should be submitted along with the associated Intertek Listing Construction Data Report (CDR) and a valid Intertek Authorization to Mark [ATM] form to the CSFM BML Program Coordinator for use under the "fast track" application process. A separate application fee payable to CAL FIRE in accordance with Title 19 of the California Code of Regulations (CCR) is required.

http://osfm.fire.ca.gov/strucfireengineer/strucfireengineer_bml

Intertek Report Number:	103946414CHI-002
Intertek Issuing Office:	Chicago
CSFM BML Category:	7256 - Ionization Smoke Detector (Single/Multiple)
Applicant/Listee:	Universal Security Instruments Inc.
Standards Used:	Smoke Alarms [UL 217:2015 Ed.8+R:23Nov2016]
Product Covered:	120Vac with non-replaceable 10 year battery back-up, single and/or multiple station smoke alarm; Or, Non-replaceable 10 year primary battery operated single station smoke alarm.
Design:	The products covered by this report are single and/or multiple station ionization type smoke alarms with silence. These alarms are intended to operate from 120Vac primary with 10 year 2 AA non-replaceable back-up batteries or from 10 year 2 AA non-replaceable primary batteries. Alarms are intended for indoor residential use only. The product shall be installed in accordance with all local codes and NFPA 72.

Engineer 

Reviewer: 

Name Mark Dippner
 Title Sr. Project Engineer
 Date January 15, 2020

Name Rich Hoffman
 Title Team Lead
 Date January 15, 2020

Product inquiries should be made to Vince Mori, Intertek Life Safety & Security Chief Engineer at (847) 718-6313.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results in referenced from this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant: Universal Security Instruments Inc.	Manufacturer: Fujian Taisun Electronics Tech Co., Ltd
Address: 11407 Cronhill Drive, Suite A Owings Mills, MD 21117	Address: Fujian-Guangdong Boarder Dev. District, North District
Country: USA	Country: Zhaoan Fujian, China
Contact: Steve Babinec Harvey Grossblatt	Contact: Sikker Chan
Phone: (410) 363-3000 x214 (410) 363-3000 x224	Phone: 852-2557-3135
FAX: (410) 363-2218	FAX: 852-2897-0249
Email: steveb@universalsecurity.com Harvey@universalsecurity.com	Email: asstsales2@Eyston.com
Party Authorized To Apply Mark: Same as Manufacturer	
Report Issuing Office: Chicago	
Control Number: <u>4005095</u>	Authorized by: <u><i>Dean Davidson</i></u> for Dean Davidson, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s): Smoke Alarms [UL 217:2015 Ed.8+R:23Nov2016]
Product: 120Vac with non-replaceable 10 year battery back-up, single and/or multiple station smoke alarm; Or, Non-replaceable 10 year primary battery operated single station smoke alarm.
Brand Name: USI Electric, Inc. or Universal.
Models: AMI1061S, AMI3051S [Provisional Listing]

