

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 5276-0899:0118 Page 1 of 1

CATEGORY: 5276 -- CARBON MONOXIDE ALARMS

LISTEE: Universal Security Instruments 11407-A Cronhill Dr., Owings Mills, MD 21117
Contact: Stephen Babinec (410) 363-3000 Ext: 214 Fax (410) 363-2218
Email: steveb@universalsecurity.com

DESIGN: Models "Universal Security Instruments" MCN400, MCND401 and "Safety Sentry" ESD006 direct plug-in (120 VAC with 9 VDC battery back-up), single station, carbon monoxide alarms. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC with 9 VDC battery back-up

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or * Trade name "Safety Sentry", model number, electrical rating, and UL label.

APPROVAL: Listed as Carbon Monoxide alarms for residential applications. Refer to listee's Installation Instructions Manual for details.

NOTE: Carbon Monoxide alarms are not intended/suitable for fire and smoke detection.

*Rev 06-04-14 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division