
QUICK FIND[®] Alarm Origination/Location Feature
Quickly identifies the first alarm to sound in an interconnected system
Models MICN109 and MDSCN111

The Quick Find[®] feature will allow you to immediately locate the **originating** alarm (the alarm that triggered the other alarms), once the alarms have stopped sounding.

1. Press and release the Test/Silence button on any alarm. After releasing the button, the test sequence on this alarm will begin, and last approximately 5-20 seconds.
2. Once this test sequence ends, the **originating alarm** continues to sound for approximately 50 seconds, which provides ample time to locate the originating alarm.
3. Remember to **reset** the originating alarm in order to clear the Quick Find[®] and to return the system to normal operation.

Reset Instructions

Press the Test/Silence button for approximately 10 seconds, or until the blue LED turns on, and then release. This will clear the alarm latching LED's and clear the alarm origination. **Reset** the system after each alarm event.

Refer to the Interconnect Compatibility section of the user's manual for additional information.
In a non-interconnected installation, it is necessary to test each alarm to determine the originating alarm.