

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7256-0899:0122

Page 1 of 1

CATEGORY: 7256 -- SMOKE ALARM-IONIZATION TYPE (SINGLE/MULTIPLE)

LISTEE: Universal Security Instruments 11407-A Cronhill Dr., Owings Mills, MD 21117
Contact: Stephen Babinec (410) 363-3000 Ext: 214 Fax (410) 363-2218
Email: steveb@universalsecurity.com

DESIGN: Models "USI Electric" MICN109, MICN109L, MDSCN111, MDSCN111L; "Safety Sentry" ESD003, ESD004, *ESD004W; "Mister Sparky" MSD004 and *MSD004W combination ionization smoke and carbon monoxide alarms. *Units have a silence/hush feature. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC with 9VDC battery back up.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Trade names "USI Electric", "Safety Sentry" "Mister Sparky", model number, electrical rating, and ETL label.

APPROVAL: Listed as single/multiple station combination ionization smoke and carbon monoxide alarms for residential applications. Refer to listee's Installation Instructions Manual for details.

NOTE: 1. The ionization type alarms are generally more effective at detecting fast, flaming fires that consume combustible materials rapidly and spread quickly. Sources of these fires may include paper burning in a waste container or a grease fire in the kitchen. The photoelectric type alarms are generally more effective at detecting slow, smoldering fires that smolder for hours before bursting into flame. Sources of these fires may include cigarettes burning in couches or bedding.

2. Meet the new smoke alarm requirement (SB 1394)

*Rev 11-10-15 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2018**

Listing Expires **June 30, 2019**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division