CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





LISTING No. 7256-0899:0114 Page 1 of 1

CATEGORY: 7256 -- SMOKE ALARM-IONIZATION TYPE (SINGLE/MULTIPLE)

LISTEE: Universal Security Instruments11407-A Cronhill Dr., Owings Mills, MD 21117

Contact: Stephen Babinec (410) 363-3000 Ext: 214 Fax (410) 363-2218

Email: steveb@universalsecurity.com

DESIGN: Models "USI Electric" MI106, MI05107, MDS107L; *"Safety Sentry" ESD002;

*"Mister Sparky" MSD002 single/multiple station, ionization smoke alarms *wish

silence/hush feature. Refer to listee's data sheet for additional detailed product description

and operational considerations.

RATING: 120 VAC with 9 VDC battery backup

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Trade names "USI Electric", *Safety Sentry", *"Mister Sparky", model

number, electrical rating, and UL label.

APPROVAL: Listed as single and single/multiple station ionization type smoke alarms. Refer to listee's

Installation Instructions Manual for details.

NOTE: 1. The ionization type alarms are generally more effective at detecting fast, flaming fires that

consume combustible materials rapidly and spread quickly. Sources of these fires may include paper burning in a waste container or a grease fire in the kitchen. The photoelectric type alarms are generally more effective at detecting slow, smoldering fires that smolder for hours before bursting into flame. Sources of these fires may include cigarettes burning in

couches or bedding.

2. *Meets the new smoke alarm requirement (SB 1394)

*Rev 09-17-15 dg



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: July 01, 2021 Listing Expires June 30, 2022

Authorized By: **DAVID CASTILLO**, M.E., F.P.E.

Fire Engineering Division