

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7125-0899:0502 Page 1 of 1

CATEGORY: 7125 -- FIRE ALARM DEVICES FOR THE HEARING IMPAIRED

LISTEE: Universal Security Instruments 11407-A Cronhill Dr., Owings Mills, MD 21117
Contact: Stephen Babinec (410) 363-3000 Ext: 214 Fax (410) 363-2218
Email: steveb@universalsecurity.com

DESIGN: Model SLW127 strobe light is a smoke alarm accessory that detects the alarm signal from listee's compatible alarms and provides a three tone temporal light output from a strobe light. The strobe lights produced light format comply with UL 1971 Standard. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 Vac

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or USI Electric, model number, electrical/candela rating, and ETL label.

APPROVAL: Listed as a strobe light for the hearing impaired when used with separately listed compatible smoke alarms. For indoor use only. Refer to listee's Installation Instructions Manual for details.

10-07019 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **October 07, 2019**

Listing Expires **June 30, 2020**

Authorized By: **DAVID CASTILLO, M.E., F.P.E., Program Coordinator**
Fire Engineering Division