

## PRODUCT IDENTIFICATION GUIDE | MODEL MPC122S

CAUTION: If your alarm is hardwired, this means wired in directly to the house wiring: IMPORTANT SAFETY WARNING! Before removing the alarm from the mounting bracket, turn off the AC power at the circuit breaker or fuse box. The green LED will now be off. Do not proceed with the product inspection if the green LED is on. Remove alarm from the mounting bracket by rotating it counterclockwise. Contact USI immediately with any questions 1-877-220-0046.

## Model MPC122S is AC Powered/Hardwired

COMPARE YOUR ALARM to the product images to the right. Affected alarms are identical to the image with the red alert symbol.

Verify your smoke alarm has USI Electric Photoelectric Smoke & Fire + Carbon Monoxide Alarm printed on the cover.

DICATE THESE MARKINGS ON THE BACK OF YOUR ALARM.

Remove the alarm from the mounting bracket by twisting it counter clockwise. Alarm is shown with AC power connector removed.

Company Name:
USI Electric

Model Number:
MPC122S

Date Manufactured:
2017JUN02





JIF YOUR ALARM IS AFFECTED —
Universal will replace your alarm at no cost. Contact us:
website: https://www.universalsecurity.com/reg-form-2022/

email: safety@universalsecurity.com

call: (877) 220.0046

IF YOUR ALARM IS NOT AFFECTED — no further action is needed. Reattach the alarm to the mounting bracket by rotating it clockwise. Turn on the AC power at the circuit breaker or fuse box. The green LED will now be on. Test the alarm by pressing the test button. The alarm will sound 3 beeps, followed by a 6 second pause, then 4 beeps. The green LED will be on and the red smoke LED will blink in sync with the 3 beeps and the red CO LED will blink in sync with the 4 beeps. Remember: Test your alarm weekly.